



Фотометрический отчет

Product Mark


Model: ДСО 21 (арт. ДКУ 92 174/4К-121Вт-170-264в ШБ-У)

Temperature: 25°C

Tester: Романов

Humidity: 65%

Test Date: 2022-02-04,13:33:09



Color parameter:

CIE:x=0.342 y=0.354/u'=0.209 v'=0.323 duv=0.002

CCT:Tc=5108.912 Dominant:λd=568.900nm Purity=8.833

Color Ratio:R=14.1% G=83.6% B=2.3% Peak:λp=446.5nm HalfWidth:λd=17.4nm

CRI:Ra=72.7

R1=70.3 R2=77.0 R3=82.4 R4=74.0 R5=71.9

R6=69.6 R7=80.1 R8=56.2 R9=-31.9 R10=46.1

R11=72.7 R12=47.3 R13=70.9 R14=90.2 R15=64.0

Photometric paramete:

Φ=18972.4lm η=158.10lm/W Φe=56.928W

Electrical parameters:

VF = 218.90V IF = 559.00mA P = 120.00W PF = 0.980

Instrument Status

Type:

SN: 201812748

Scan Range: 380-780nm

Integral Time:8.645ms

VPeak: 62743

VDark: 2024

Remark: